

The right choice for ultimate yield!

LS ELECTRIC strives to maximize your profits in gratitude for choosing us as your partner.

Digital Protection Relay

GIPAM115

User's Manual

GIPAM Series



Safety Instructions

- Read this manual carefully before installing, wiring, operating, servicing or inspecting this equipment.
- Keep this manual within easy reach for quick reference.

LSELECTRIC

The best choice for your benefit.

LS ELECTRIC makes an effort to give more benefit to user.

A table of contents

• Safety precaution	3
1. The Layout of MMI	6
2. The ratings of GIPAM-115 FI	9
3. Protection relay	10
4. MENU Setting	12
5. Self diagnosis	20
6. The specification of user interface	21
7. Inverse time curve	26
8. External dimension	30
9. Ordering information	31



Safety Caution

Please read carefully before product being taken into Service to ensure safety and proper operation of GIPAM-115FI

- Please keep the safety caution to prevent any accident may happen by using the products incorrectly.
- Safety caution is classified with caution and danger and indication of them as follows.



Caution

Not following the instruction may result in serious injury or even death



Danger

Not following the instruction may result in serious injury or property damage.

- Symbols used in this manual indicate as follows.



This symbol is for warning the hazardousness under the specific condition



This symbol is for warning the electric shocks or any accidents under the specific condition



Warning

- Please do not operate, inspect, and install by yourself.
- Please do not wiring when applied with power or on the operation; it may result in electric shock.
- Please do not all the wiring operation with the live bus bar; it may result in electric shock or fire and property damage by charging voltage of current transformer.

- **Please put to earth;** it may result in electric shock.
- **Please do not attempt to disassemble even when the power not applied;** it may result in electric shock by charging current remained in the product.
- **Please do not short-circuit the secondary part of PT;** it may result in fire.
- **Please do not disconnect the secondary part of CT;** it may result in fire or explosives.
- **Please do not wire or operate with wet hands;** it may result in electric shock.
- **Please do not use any damaged cable;** it may result in electric shock.
- **Please use the ring terminal when wiring the cable;** it may result in electric shock by bare wire.



Warning


■ Safety caution for installation & terminal wiring

- **Apply the rated voltage to the power supply terminal;** it may result in property damage or fire.
- **Please keep away product from screws, metals, water, or oil;** it may result in fire.
- **Please keep the rated load and polarity of input & output contacts;** it may result in property damage or fire.
- **Please wire to the terminal block after checking the terminal number;** it may result in property damage or fire.

- Please assemble terminal cover after wiring the terminal.
- Specialist help shall be sought for the installation and maintenance of product; it may result in malfunction or accident.
- Please use aux. relay for closing/opening of breaker; it may result in the burn of inside relay if the breaker controlled directly.
- Inspection item before power supply being applied
 - Check the voltage or polarity of control power supply.
 - Check the wiring condition of input / output terminal.
- Caution for storage & handing
 - Please store dry & clean place.
 - Please do not throw or put force on it during transport; it may result in malfunction or wrong operation.
- Caution for disposal
 - Please dispose of it in accordance with industrial waste regulation.

1. The Layout of MMI

1.1 The External View



- | | |
|--|--|
| 1. LCD Display | 12. CB ON key (Red LED) |
| 2. Fault Indicator Reset Switch | 13. CB OFF key (Green LED) |
| 3. 16 × 2 LCD | 14. Local key (Yellow LED) |
| 4. Fault Indicator LED | <ul style="list-style-type: none"> • Local output contact |
| 5. Relay Set / Run key | <ul style="list-style-type: none"> • Manual operation of CB ON/OFF |
| 6. ESC key | 15. Remote key (Yellow LED) |
| <ul style="list-style-type: none"> • Cancel or Move to upper menu | <ul style="list-style-type: none"> • Remote output contact |
| 7. Enter key | <ul style="list-style-type: none"> • Remote operation of CB ON/OFF |
| <ul style="list-style-type: none"> • Saving of changed data / Clear execution | 16. Clear Key |
| 8. Decrement key | <ul style="list-style-type: none"> • Wh / Varh, The number of CB operation, • CB conducting time, Clear max. Vo (zero) |
| <ul style="list-style-type: none"> • Decrease data or Move between items | 17. CPU Reset Key |
| 9. Increment key | 18. Protection Cover |
| <ul style="list-style-type: none"> • Increase data or Move between items | 19. COMM LED (Red) |
| 10. Display Select key | <ul style="list-style-type: none"> • Blinking during communication |
| 11. Function key (Red LED) | 20. POWER LED (Red) |

1. The Layout of MMI

1.2 Configuration

A) The basic function & operation of keys on GIPAM-115FI

The key on the surface of GIPAM-115FI has its own function according to each menu.


The type of key	Applicable menu	Basic function
Direction key (Up, Down)/ (DEC, INC)	Menu tree	Move between items
	Correcting & setting menu	Move to the data which will be set
ENT key	Correcting & setting menu	The saving of changed data or removing of saved data
	Menu tree	Move to the menu where cursor is on
ESC key	Correcting & setting menu	The cancel of changed data
	Menu tree	Move to upper menu
SET/RUN key	Relay setting menu	Selecting the relay which will be used or Moving to relay setting menu
CLOSE key OPEN key	Menu tree	The control of CB
		Close Key is for the close of CB Open Key is for the open of CB
LOCAL key REMOTE key	Menu tree	The switching of Remote and Local
CLEAR key	Menu tree	Reset the accumulated values Ex) Wh, Varh, CB ON time, CB operation count, Vo max.

B) The basic function & operation of LED on GIPAM-115FI

The type of LED	Basic function
POWER LED	It is with red and indicates the status of power supply For normal operation it is kept with red light ON
COMM LED	It is with red and indicates the status of remote communication. The LED is blinking while transmitting or receiving data under normal correspondence of communication card.
PICK-UP/TRIP LED (OCR,OCGR,OVR,UVR, OVGR,SGR,POR)	It is with red and indicates the protection relay. It is blinking every second if protection relay is in the condition of Pick-up by systematic faults. It is kept with red light ON if it is tripped by the operation of protection relay. This LED can be cancelled only by RESET KEY of protection relay or reset of it with remote communication.
REMOTE/LOCAL	It is on the upper side of R/L KEY with yellow and indicates the present control status
CB CLOSE/OPEN	It is on the upper side of CLOSE/OPEN KEY with green & red and indicates the present status of circuit breaker which is connected to GIPAM-115FI. Red LED is ON when CB is closed and Green LED is ON when CB is opened.

1. The Layout of MMI

1.3 Menu tree



2. Ratings

2.1 The ratings and measuring specification

The ratings

Item		Spec.
Wiring connection		1P2W, 1P3W, 3P3W, 3P4W
Input contact	Frequency	60Hz (50Hz)
	Rated voltage	PT: AC110V or AC100V GPT : AC190V
	Rated current	CT : 5A
		ZCT : (SGR :1.5mA), (OCGR :5A)
	Control voltage	AC110V, DC110/125V (or DC110V±20%)
	Power consumption	Under 15W
Output contact	Input burden	PT : under 0.5VA
		CT : under 1.0VA
	Contact switching capacity	AC250V 16A / DC30V 16A
Relay for signal	Max. switching capacity	4000VA, 480W
	Contact switching capacity	AC250V 5A / DC30V 5A
	Max. switching capacity	1250VA, 150W
Operating temperature range		-10℃ ~ 55℃
Storage temperature range		-25℃ ~ 70℃
Relative humidity		Under 80% (Shall not reach the dew point)
Altitude		Under 2,000m
Others		Shall be no abnormal vibration & impact Shall be no severe air pollution
Applicable standard		KEMC 1120, IEC 60255, IEC 61000

Measuring specification

Type	Range	Remark
Voltage (V)	(0.5~ 414,000V)	* PT ratio setting : (Primary)110 ~ 345000V/1V, (Secondary)110V or 100V
Zero phase voltage (Vo)	(0.5~ 190V)	-
Line-to-line current (I)	(0, 0.05~7,200A)	* CT ratio setting : 5 ~ 6000A/1A
Power Factor (PF)	(Lead/Lag 0~1)	* PF=0 (Under min. measuring V or I) or (P<0) * Lead (Q<0), Lag (Q>=0)
Frequency (F)	(45 ~ 65 [Hz])	* F=0 (under 45[Hz] or over 65[Hz]) or (Secondary voltage of PT: under50V)
Active power (W)	(0 ~ 9,999[MW])	* W=0 (Under min. measuring Voltage or Current) or (PF<0)
Reactive power (VAR)	(0 ~ 9,999[MVAR])	* Var=0 (Under min. measuring Voltage or Current)
Active electric energy (MWh)	(0~999,999[MWh], Bar Graph 12ea)	*The increase of Graphic bar on LCE by 5EA in case of Roll_over
Reactive electric energy (MWh)	(0~999,999[MVARh], Bar Graph 12ea)	

3. Protection Relay

GIPAM-115FI RELAY SETTING

Protection relay	Operation type	Operating value setting / Increase & Decrease, Operating time	Remark
OCR(50/51)	HIGH	Setting : Off, 2~24/1In (In = 5A) Operating time : 0.04~60.0/0.01s	Definite time : D2,D4,D8 Inver time curve: SI, VI, EI, LI OUT MODE : --, AL, TP
	LOW	Setting : Off, 0.2~10.0/0.1In Operating time : 0.05~1.20/0.01	
OCGR (50/51N)	HIGH	Setting : Off, 0.5~8.0/0.5In Operating time : 0.04~60.0/0.01s	Definite time : D2,D4,D8 Inver time curve: SI, VI, EI, LI OUT MODE : --, AL, TP
	LOW	Setting : Off, 0.1~0.5/0.02In Operating time : 0.05~1.20/0.01	
	OCGR block	Block Time : 0.1~60.0/0.1s	OCGR function is blocked during the setting time when starting motor (Applying over 1A of phase current).
SGR (67G)	-	Io setting : Off, 0.6~3.6/0.2Ion (Ion=1.5mA) Vo setting : 0.1~0.4/0.02Von (Von=190V) MTA: 45° Operating time : 0.1~60.00/0.01s GR MODE : ON/OFF (Only Io operates under GR MODE)	Non-earth type Definite time OUT MODE : --, AL, TP
OVR (59)	HIGH	Setting : OFF, 0.80~1.60Vn/0.02Vn (Vn = 100 or 110V) Operating time : 0.1 ~ 60.0s / 0.01s	Definite time OUT MODE : --, AL, TP
	LOW	Setting : OFF, 0.80~1.60Vn/0.02Vn Operating time : 0.1 ~ 60.0s / 0.01s	
UVR (27)	HIGH	Setting : OFF, 0.20~0.90Vn/0.02Vn Operating time : 0.1 ~ 60.0s / 0.01s	Definite time OUT MODE : --, AL, TP, TA
	LOW	Setting : OFF, 0.20~0.90Vn/0.02Vn Operating time : 0.1 ~ 60.0s / 0.01s	
	UVR LOCK	Do not operate under 15V (3 phase voltage)	
OVGR (64)	HIGH	Setting : OFF, 0.10~0.40Von/0.02Von (Von=190V) Operating time : 0.1 ~ 60.0s / 0.01s	Definite time OUT MODE : --, AL, TP
	LOW	Setting : OFF, 0.10~0.40Von/0.02Von (Von=190V) Operating time : 0.1 ~ 60.0s / 0.01s	

3. Protection Relay

GIPAM-115FI RELAY SETTING

Protection relay	Operation type	Operating value setting / Increase & Decrease, Operating time	Remark
POR (47)	HIGH	Setting : OFF, 5~100%/1% Operating time : 0.1 ~ 60.0s / 0.01s	Definite time OUT MODE : ---, AL, TP
	LOW	Setting : OFF, 5~100%/1% Operating time : 0.1 ~ 60.0s / 0.01s	

※ Definite time calculation

$t = T \times \text{tap}$ (second)

- Definite time (D2) T=2
- Definite time (D4) T=4
- Definite time (D8) T=8

* Precautions on how to use the SGR(67G) GR MODE

GR MODE ON : Regardless of the zero-sequence voltage and phase angle, Relay operate only the size of zero-sequence current.(When SGR is used, GR MODE should be OFF)

GR MODE OFF : Relay operate by the zero-sequence voltage, zero-sequence current and phase angle.

※ OCGR(50N/51N) and SGR(67G) can not be used simultaneously


- When use OCGR, SGR can not be used.
- When use SGR, OCGR can not be used.

4. MENU Setting

4.1 Relay part view


A) Initial window

The initial window will be displayed as shown in below after applying the power supply to the device



B) The window of basic menu

If pressing SET/RUN key from initial window, move to basic menu window. It is the most fundamental window which displays the lists of menu. DEC/INC key are used for the move of different menus and the detailed menu is available by pressing ENTER key.



The basic menu window of GIPAM-115FI is as shown in above figures. The menu will be selected if pressing ENTER key after moving to the desirable menu by DEC/INC key.

4. MENU Setting

4.1 Relay part view

C) The subordinate menus

1. RELAY SETTING

→ 1 . [*] O C R
2 . [] O C G R

3 . [] S G R
4 . [] O V R

5 . [*] U V R
6 . [*] O V G R

7 . [] P O R

(Fig.: It indicates that OCR, UVR, OVGR are selected from RELAY SETTING)

Press SET/RUN key to distinguish whether protection relay will be used or not after moving to the desirable protection relay by DEC/INC key.

OUT MODE: --, AL, TP, TA

* None (--): Pick up/Trip LED ON

* AL: Pick up/Trip LED ON + Alarm DO + Protection relay DO operation

* TP: Pick up/Trip LED ON + Alarm DO + Protection relay DO + CB OFF contact operation

* TA: Pick up/Trip LED ON + Alarm DO + Protection relay DO + CB OFF contact + Auto Reset

2. MEASUREMENT

1 . R E L A Y S E T T I N G
→ 2 . M E A S U R E M E N T

4. MENU Setting

4.1 Relay part view

The following subordinate menus are available from 2. Measurement.

```
1 . V O L T A G E
2 . C U R R E N T
```

```
3 . V - I      A N G L E
4 . V          U N B A L A N C E
```

```
5 . D I
```

3. EVENT / FAULT

```
→ 3 . E V E N T / F A U L T
   4 . C O M M   S E T T I N G
```

The following subordinate menus are available from 3. EVENT/FAULT.

```
1 . E V E N T   L I S T
2 . F A U L T   L I S T
```

```
3 . C L E A R   E V E N T
4 . C L E A R   F A U L T
```

3.1) Clear Event/Fault

```
→ 3 . C L E A R   E V E N T
   4 . C L E A R   F A U L T
```




Press ENT key




```
E V E N T   C L E A R ?
                N O
```

4. MENU Setting




4.1 Relay part view



4. COMM Setting



The following subordinate menus are available from 4. COMM SETTING



4-1) COMM Type: I-NET, MODBUS

4-2) Address: 1~254 / 1UNIT (I-NET)

1~247 / 1UNIT (MODBUS)

4-3) Baud Rate: 9600, 19200, 38400 (only MODBUS)

4-4) Swap: ON/OFF (only MODBUS)

4-5) I-NET old version: GIPAM115N (device ID 0x83) or GIPAM115F (device ID 0x93)

4. MENU Setting

4.1 Relay part view

5. PT / CT SETTING

→ 5 . P T / C T S E T T I N G
6 . T I M E

The following subordinate menus are available from 5. PT/CT SETTING.

1 . W I R I N G
2 . C T S E T

3 . P T S E T
4 . S e c o n d P T V o l

5-1) WIRING: The value can be changeable by pressing DEC/INC key (1P2W, 1P3W, 3P3W, 3P4W)

5-2) CT Set: The value can be changeable by pressing DEC/INC key (5~6000/1UNIT)

5-3) PT Set: The value can be changeable by pressing DEC/INC key (110~345000/1UNIT)

5-4) SECOND PT VOL: The value can be changeable by pressing DEC/INC key (100, 110)

* Caution: If changing the setting value of primary /secondary CT and PT, the values of WH and VARH are reset.

6. TIME

5 . P T / C T S E T T I N G
→ 6 . T I M E

The following subordinate menus are available from 6. TIME.

1 . V I E W T I M E
2 . S E T T I M E

4. MENU Setting

4.1 Relay part view

6-1) SET Time

1 . V I E W T I M E
→ 2 . S E T T I M E



Press ENT key after selecting the desirable menu by DEC/INC key.



S E T	2 0 0 0	:	3	:	1 8
T I M E	0 7	:	2 9	:	2 5



Setting value can be changeable in the range of 2000.01 ~ 2099.12.31 23:59:59.

7. SYSTEM INFO

→ 7 . S Y S T E M I N F O

The following subordinate menus are available from 7. SYSTEM INFO.

1 . I E D	D i a g n o s i s
2 . S y s	V e r s i o n

4. MENU Setting

4.1 Relay part view

D) The table of EVENT / FAULT


1. Event recording list: available to save 128 events.

Class	Contents	Remarks
Relay Pick Up	Picked-up Relay , Time Tag	
Relay Operation	Operated Relay , Time Tag	
Relay Trip (Fault)	Operated Relay, Time Tag	Relay Operation + CB open
DI COS	Change of DI Status, Time Tag	De-bounce Time
DO COS	Change of DO Status, Time Tag	
Control	CB, Control Contact, Power ON	
Relay Setting	Change of Relay Setting Parameter	
System Configuration	Change of System Configuration	

2. Fault recording list: available to save 32 faults

Fault Value: VR, VS, VT, IR, IS, IT, IN, Io, Vo, Vn, Anr, Ans, Ant, Ano

※ FAULT recording window



4. MENU Setting

4.1 Relay part view

The measured value can be checked by pressing the desirable keys on front measurement part.



: Voltage [RN → SN → TN → RS → ST → RT]



: Current [Ir → Is → It]



: Active power



: Reactive electric energy



: Reactive power



: Frequency



: Active electric energy



: Power factor

Particular function mode



+



: Display of PT ratio



+



: Display of CT ratio



+



: Display of selected wiring connection



+



: Display of communication address preset in communication part of Main Board



+



: Display of the operating numbers of CB



+



: V→A→W→Var→Wh→Varh→F→PF (Every phase of voltage/current)



+



: Display of CB ON time



+



: N1 –Display of zero phase voltage (Vo), N2 – Display of max. zero phase voltage (Vomax)

5. Self-diagnosis

5.1 Self-diagnosis configuration

Error Code is displayed on LCD of measurement part in case of being under self-diagnosis and the error codes are as follows.

The meaning of error code

- ERROR 101 : CT/PT Calibration error
- ERROR 102 : Interrupt error
- ERROR 103 : Software Run error
- ERROR 104 : Setting value error
- ERROR 105 : Calibration error
- ERROR 301 : CPU interface error

Error type	Operation
- Power Fail	<p>GIPAM115 always checks system voltage.</p> <p>When the voltage drops under predetermined level, LCD shows "P-F".</p> <p>Once power fail status is released, the system returns to normal operation status.</p> <p>※ It is cautious that WH, Varh can be cleared by CLEAR KEY during the operation of POWER FAIL.</p>
- C/PT Calibration Error	<p>GIPAM115 monitors the execution of CT/PT calibration and LCD shows "No Calib" if data is not valid or system is not calibrated correctly. When calibration is done, it turns back to normal.</p>
- Watch Dog	<p>GIPAM115 monitors whether CPU operation is normal or not. When CPU operates abnormally, watchdog IC forces CPU and periphery device to be reset. If performing reset, it reboots the operating system in the same order with power source booting and there are no other particular marks.</p>
- Relay Setting Error	<p>GIPAM115 displays as "SET" if problem occurs in setting value which relates to the operation of protection relays during booting it.</p>
- AD Converting Part Error	<p>GIPAM115 displays as "ADC" when problem occurs to the circuit of converting part of internal analog.</p>

6. The specification of User Interface

6.1 Configuration of terminal block

[OUTPUT Terminal]				[INPUT Terminal]			
A01	OCR	ALARM+	A02	B01	IR+	IR-	B02
A03	OCGR/SGR	ALARM-	A04	B03	IS+	IS-	B04
A05	OVR	Aux DI+	A06	B05	IT+	IT-	B06
A07	UVR	Aux DI-	A08	B07	In+	In-	B08
A09	OVGR	REMOTE	A10	B09	VR+	VR-	B10
A11	POR	LOCAL	A12	B11	VS+	VS-	B12
A13	F.G	L/R COM	A14	B13	VT+	VT-	B14
A15	ALARM COM	RX+	A16	B15	Io+	Io-	B16
A17	CB ON+	RX-	A18	B17	CB ON+	CB OFF+	B18
A19	CB ON-	TX+	A20	B19	CB ON-	CB OFF-	B20
A21	CB OFF+	TX-	A22	B21	Vo(+)	DC+	B22
A23	CB OFF-	COMM GND	A24	B23	Vo(-)	DC-	B24


* Precautions for F,G(A13) wiring

- F,G(A13) terminal should be grounded with switchgear panel enclosure.
- F,G(Frame Ground) is grounded to the equipment enclosure or enclosure of the distribution panel. When electrical abnormalities occurring, it inhibit electrical shock by discharge leakage current and electrical noise to ground.


6. The specification of User Interface

6.2 Wiring diagram of GIPAM-115 FI

(1) 1P 2W: 1CT, 1PT




(2) 1P 3W: 2CT, 2PT




6. The specification of User Interface

6.2 Wiring diagram of GIPAM-115 FI

(3) 3P 3W : 2CT, 2PT




(4) 3P 3W: 3CT, 2PT




6. The specification of User Interface

6.2 Wiring diagram of GIPAM-115 FI

(5) 3P 3W: 3CT, 3PT




(6) 3P 4W: 3CT, 3PT



7. Inverse time Curve

7.2 Very Inverse Time



$$t = \frac{0.14}{(I / I_s)^{0.02}} \times TL$$

t = operating time

I = fault value


I_s = setting value

TL = Time Lever

(Time setting value based on
characteristic curve)

7. Inverse time Curve


7.2 Very Inverse Time



$$t = \frac{13.5}{(I / I_s) - 1} \times T_L$$

7. Inverse time Curve


7.3 Extremely Inverse Time



$$t = \frac{80}{(I / I_s)^2 - 1} \times T_L$$

7. Inverse time Curve


7.4 Long Inverse Time



$$t = \frac{120}{(I / I_s) - 1} \times TL$$


8. External dimension

8.1 External dimension of GIPAM-115 FI



9. Ordering information

9.1 Ordering information of GIPAM-115 FI





www.lselectric.co.kr

LS ELECTRIC Co., Ltd.

79562711010

LSELECTRIC



Technical Question or After-sales Service

Customer Center - Quick Responsive Service, Excellent technical support

TEL. **82-1644-5481** | Home page. www.lselectric.co.kr

Specifications in this instruction manual are subject to change without notice due to continuous products development and improvement.

GIPAM115 / 2020.06