



SDS-600-100R-75



COMPONENT ARRANGEMENT



DESIGN DATA

| | | | |
|---------------------|---------------------|----------|--------------------|
| CODE | N/A | | |
| UNIT | mm | | |
| KIND OF FLUID | - | | |
| PRESS. | DESIGN | Max. 5 | Kg/Cm ² |
| | OPERATING | - | Kg/Cm ² |
| TEMP. (SENSOR) | DESIGN | - | °C |
| | OPERATING | - | °C |
| TEMP. (ELECTRONICS) | DESIGN | -20 ~ 60 | °C |
| | OPERATING | - | °C |
| SP.GR. | MORE THAN 0.98 | | |
| VISCOSITY | 10 P / 1 Pa.s | | |
| ENCLOSURE | WEATHER PROOF | | |
| FLANGE SIZE | JIS 10K 80A FF 6.0t | | |
| FLOAT TYPE | ø52x60L | | |
| CALIBRATION | ZERO AND SPAN | | |
| POWER SUPPLY | 15~32V DC | | |
| OUTPUT SIGNAL | 4~20mA | | |

NOTES

1. () Dimensions are reference dimensions.

REVISION

| | | | | | |
|---|---------------|--------------|---|--|---------|
| 9 | TERMINALS | | 1 | | ST-600R |
| 8 | SPAN DIAL | | 1 | | ST-600R |
| 7 | ZERO DIAL | | 1 | | ST-600R |
| 6 | STEM | 316SS/316LSS | 1 | | |
| 5 | FLOAT | 316SS/316LSS | 1 | | |
| 4 | FLOAT STOPPER | 316SS/316LSS | 2 | | |
| 3 | FLANGE | 316SS/316LSS | 1 | | |
| 2 | HOUSING | ADC12 | 1 | | |
| 1 | COVER | ADC12 | 1 | | |

| NO | DESCRIPTION | MATERIAL | Q'TY | SPECIFICATION | REMARK |
|----|-------------|----------|------|---------------|--------|
|----|-------------|----------|------|---------------|--------|

BILL OF MATERIAL

| | | | | | |
|--------------|--|--|--|--|--|
| CUSTOMER | - | | | | |
| PROJECT | - | | | | |
| TITLE | FLOAT TYPE LEVEL TRANSMITTER ST-600-B-1-A-1-D-2-A ASSEMBLY DRAWING | | | | |
| MANUFACTURER | SeoJin Instech Co., Ltd. | | | | |

| | | | | | | | |
|-------|---------|----------|------|----------------|---|------|--|
| SCALE | DRG NO. | DRG CODE | 0000 | Work Order No. | - | REV. | |
| N/S | | | | | | | |

| △ | | | | | | | |
|------|-------------|------|----------|---------|----------|----------|--|
| △ | | | | | | | |
| △ | | | | | | | |
| △ | | | | | | | |
| △ | | | | | | | |
| REV. | DESCRIPTION | DATE | DESIGNED | CHECKED | REVIEWED | APPROVED | |