

## WIRING DIAGRAM

## NOTES

- ### A. FLANGE MATERIAL

- ☒ 304SS  
☐ 316SS  
☐ 316LSS  
☐ Etc. ( )

- ### B. FLANGE SIZE

- ☒ JIS 10K 50A FF  
☐ JIS 10K 65A FF  
☐ JIS 10K 80A FF  
☐ JIS 10K 100A FF  
☐ Etc.( )

- ### C. CONDUCT CONNECTION

- ☒ PF1/2"
- ☐ PT1/2"
- ☐ PF3/4"
- ☐ PT3/4"
- ☐ NPT1/2"
- ☐ NPT3/4"
- ☐ Etc. ( )

REV.	DESCRIPTION	DATE	DESIGNED	REVIEWED	APPROVED
△					
△					
△					
△					
△	FOR APPROVAL				

DESIGN DATA			
CODE	N/A		
UNIT	mm		
KIND OF FLUID		-	
PRESS.	DESIGN		
	OPERATING	3(Max.)	Kg/Cm <sup>2</sup>
TEMP.	DESIGN	-	Kg/Cm <sup>2</sup>
(SENSOR)	OPERATING	-20 ~ 70	°C
TEMP.	DESIGN	-	°C
(ELECTRONICS)	OPERATING	-20 ~ 70	°C
CONTACT RATING		-	°C
POWER SUPPLY		DC 15 ~ 36V	
ENCLOSURE		WEATHER PROOF	
OUTPUT		4 to 20 mA DC (2 Wire) /LOD With Backlight	
VISCOSITY		1Pas /10P Less	
MOISTURE		Max 80%RH	
COMPENSATION Temp.		0 ~ 50 °C	
ACCURACY		±0.25% of F.S.	
APPLICATION		SUBMERGIBLE LIQUID	L/T

## NOTES











1. 전송기는 밀폐된 공간에 설치하면 안되며, 다가람이 유지되는 공간에 설치되어야 한다.
2. 설치 시 센서를 내부에 이물질이 쌓이지 않도록 조치 후 설치해야 한다.

## REVISION

5	FLANGE	NOTE A/C	1	
4	CABLE	Updharma & SJS Wm Amrood	m	
3	CONNECTOR	304SS	1	
2	DISPLAY HOUSING	ADC12	1	
1	SENSOR HOUSING	316LSS	1	
NO	DESCRIPTION	MATERIAL	Q'TY	SPECIFICATION
				REMARK

## BILL OF MATERIAL

CUSTOMER	-
PROJECT	-

TITLE						
PRESSURE TYPE LEVEL TRANSMITTER SPT-1-B-1-A-1-A-1-1 ASSEMBLY DRAWING						
MANUFACTURER						
 <b>Seodin Instech Co., Ltd.</b>						
SCALE	<table><tr><td></td><td></td><td></td></tr></table>					
						
DWG. NO.	ISO CODE	WORK ORDER NO.				
SJ-M019-DWG-AP002	0000	-				
		REV.				
		