

NOTES

- | REV. | DESCRIPTION | DATE | DESIGNED | REVIEWED | APPROVED |
|------|--------------|------|----------|----------|----------|
| △ | | | | | |
| △ | | | | | |
| △ | | | | | |
| △ | | | | | |
| △ | FOR APPROVAL | | | | |

CODE	N/A
UNIT	mm

KIND OF FLUID	—
PRESS.	3(Max.) Kg/Cm ²
DESIGN OPERATING	— Kg/Cm ²
TEMP.	—20 ~ 70 °C
TEMP. (SENSOR)	— °C
TEMP. DESIGN	—20 ~ 70 °C
(ELECTRONICS) OPERATING	— °C
CONTACT RATING	—
POWER SUPPLY	DC 15 ~ 36V
ENCLOSURE	WEATHER PROOF
OUTPUT	4 to 20 mA DC (2 Wmax) /CO With Backlight
VISCOSITY	1Pa.s /10P Less
MOISTURE	Max 80%RH
COMPENSATION Temp.	0 ~ 50 °C
ACCURACY	±0.25% of F.S.
APPLICATION	SUBMERGIBLE LIQUID L/T

MEASURING RANGE	(m) Max. 30m
TAG NO.	-

NOTES











1. 전승가는 밀폐된 공간에 설치하면 안되며, 다기암이 유지되는 공간에 설치되어야 한다.
2. 설치 시 센서를 내부에 이물질이 쌓이지 않도록 조치 후 설치해야 한다.

REVISION

NO	DESCRIPTION	MATERIAL	QTY	SPECIFICATION	REMARK
6	WEIGHT	304SS	1		
5	FLANGE	NOTE A/C	1		
4	CABLE	UNIPHY & 3/8 INCHES 304SS	m		
3	CONNECTOR	304SS	1		
2	DISPLAY HOUSING	ADCI2	1		
1	SENSOR HOUSING	316LSS	1		

BILL OF MATERIAL

CUSTOMER	-
PROJECT	-

TITLE						
PRESSURE TYPE LEVEL TRANSMITTER SPT-1-B-1-A-1-B-1-A ASSEMBLY DRAWING						
MANUFACTURER						
 Seojin Instech Co., Ltd.						
SCALE	<table><tr><td></td><td></td><td></td></tr></table>					
						
DWG. NO.	ISIRI CODE	WORK ORDER NO.				
SJ-M019-DWG-AP005	0000	-				
			REV.			
			