


INSTALLATION DRAWING



WIRING DIAGRAM

△									
△									
△									
△									
△	FOR APPROVAL								
REV	DESCRIPTION	DATE	DESIGNED	REVIEWED	APPROVED				

DESIGN DATA

CODE	N/A
UNIT	mm
KIND OF FLUID	-
PRESS.	DESIGN -
	OPERATING -
TEMP. (SENSOR)	DESIGN -20 ~ 85 °C
	OPERATING -
TEMP. (ELECTRONICS)	DESIGN -10 ~ 60 °C
	OPERATING -
MEASURING RANGE	Max 10 M
SPECIFIC GRAVITY	More than 0.6
MOISTURE	Max 95% RH
INPUT POWER	Max 10 M
OUTPUT	DIAL DISPLAY
ACCURACY	±20mm
MOUNTING SIZE	PF 2"
LOOP IMPEDANCE	450 Ω (20V DC)
CALIBRATION	ZERO & SPAN

TAG NO.	L	L1	L2

NOTES

REVISION

6	FLOAT	304SS	1		
5	SPRING	304SS	1		
4	WIRE	316SS	1		
3	FLANGE	304SS	1		
2	CONVERTER	ABS	1		
1	BODY	ABS	1		

NO	DESCRIPTION	MATERIAL	QTY	SPECIFICATION	REMARK
----	-------------	----------	-----	---------------	--------

BILL OF MATERIAL

CUSTOMER			
PROJECT			
TITLE			
GEAR TYPE LIQUID LEVEL TRANSMITTER			
SQL-2-A-1-E-1-A			
ASSEMBLY DRAWING			
MANUFACTURER			
Seojin Instech Co., Ltd.			
SCALE	UNIT	TEMP CODE	WORK ORDER NO.
N/S	mm	0000	-
TAG NO.		SU-M008-DWG-AP008	
REV		1	