

600V Instrumentation/control cable

FR-EPR/CR, FR-EPR/CSP

Construction

1 Conductor

Tin-coated annealed strand copper conductor(class B)

2 Insulation

EPR

3 Individual shield

copper / mylar tape with tinned copper drain wire


4 Drain wire

5 Overall shield

copper / mylar tape with tinned copper drain wire

6 Jacket

Chlorosulphonated polyethylene(CSP)–Heavy duty
Chloroprene(CR)–Heavy duty



XHHW

Construction

1 Conductor

Tin-coated annealed strand copper conductor(class B)

2 Insulation

Cross-linked sythetic polymer(XHHW)

